

FIRE SAFETY CERTIFICATE

APPENDIX - XII

No.

Dated: 07/12/2024

Certified that the Pioneer Public School SR NO 111 Ghule Wasti Near New Serum (name of the building or premises) at Manjari BK Pune - 412307..... (address) comprised of Ground and First Floor (upper floors) owned/ occupied by Pioneer Public School (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 07/12/2024 (date of inspection) in the presence of Amit Jambhulkar (name and addresses of the Manager/ Secretary or his representative) and that the building/ premises is fit for occupancy upto classes XII (X/ XII) With effect from 07/12/2024 for a period of One year in accordance with rule and subject to compliance of specific conditions as appended:-

1. Keep all safety equipment at proper place.
2. Train all staff how to operate equipment.
3. Keep record of moe drill.
4. Keep all equipment update and interact in working condition. The whole responsibility will be of the management of Pioneer Public School

Issued on 07/12/2024 (date of issue) at Pioneer Public School (place) by

*Strike out whichever is not applicable.

Signature with Seal:

Name

Ankush Tambare

Designation

Owner

Name & Address of Department/ Office: Manjari BK

To

Pioneer Public School

Sr No 111 Ghule Wasti Near New
Serum Manjari BK Pune - 412307

(Name & Address of the Institution)

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled an annulled due to

(reasons to be recorded).

(Name and designation of the authorized signatory)

* The filled-up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

Plat No,4 Yogdeep Building ,sai Balaji Green Society ,Manjari Bk Near Shivaji Chowk -412307
Email-Id:ankushfiresafetyenterprises@gmail.com Mobile No: 8208744087/9921643793
GSTIN No: 27AXVPT1810H1Z2

Fire Extinguisher Refilling Certificate

Date 24-Jan-2025

To,
PIONEER PUBLIC SCHOOL
Manjari Pune-412307

Sub: Certificate for the Refilling of Fire Extinguishers.

This is to Certify that following fire extinguishers have been Refilled by us
as per BIS code of practice 'IS 2190' & Relevant Specification ,Also It Will be having
one year warranty from the date of refilling.

Sr.no.	Type of Extinguisher	Capacity	Qty in nos	Remark
01	ABC	2 kg	2	Ok
02	ABC	4 kg	2	Ok
03	ABC	6 Kg	6	Ok

Date of Refilling :-
24-Jan-2025

Next Due Date for Refilling :-
23-Jan-2026

Thanks And Regards

Ankush Fire Safety Enterprises